

Inspection Report



Establishment Name:	McDonalds
Establishment Address:	1 Market Street, Leicester
Food Business Operator:	McDonalds Restaurants Ltd

Reference:	19160/0001/0/000
Date:	4 March 2013
Inspection Date:	25 February 2013
Next Inspection:	January 2014

Inspector:	[REDACTED]
Telephone:	[REDACTED]
Fax:	[REDACTED]
E-mail:	[REDACTED]

On 25 February 2013 I revisited the above premises to check compliance.

The items listed in this report are contraventions of current legal requirements, except where indicated as **Advice**. The contraventions should be put right within the timescales indicated, which begin on the date that you receive this report.

When you wish to apply for a re rating under the Food Hygiene Rating Scheme please send an email to food@leicester.gov.uk

For further information and advice about food safety, visit www.leicester.gov.uk/food or contact me directly.

cc. Manager, McDonalds, 1 Market Street, Leicester.

No.	Regulation	Contravention	Action Required	Timescale
Cleaning and Maintenance				
1	Regulation (EC) No 852/2004 Annex II Chapter I Paragraph 1	In the dry store the floor was split on the middle join.	The floor needs to be repaired.	Immediate
2	Regulation (EC) No 852/2004 Annex II Chapter I Paragraph 1	There were some cracked coving wall tiles by the washing machine.	The tiles must be replaced..	Immediate
3	Regulation (EC) No 852/2004 Annex II Chapter I Paragraph 1	In the boiler room there were holes in the walls (used for services) that could allow pest access.	The holes need to be fitted with doors or mesh covers.	Immediate
Equipment				
4	Regulation (EC) No 852/2004 Annex II Chapter V Paragraph 1	By the office the bottom seal to the display fridge was split.	The door seal needs to be replaced.	Immediate
5	Regulation (EC) No 852/2004 Annex II Chapter V Paragraph 1(c)	There was ice on the front of the door to the walk in freezer and the bottom of the door seal was damaged.	The ice needs to be removed and the seal repaired / replaced.	Immediate
Food Waste				
6	Regulation (EC) No 852/2004 Annex II Chapter VI Paragraph	In the rear yard I found an accumulation of food waste by the entrance doors.	The manager agreed to have the accumulation cleaned up by his staff even though most of the waste did not appear to originate at McDonalds.	Immediate

No.	Regulation	Contravention	Action Required	Timescale
Health and Safety				
7	The Workplace (Health, Safety and Welfare) Regulations 1992, Regulation 12(1)	The metal ramp leading to the walk in freezer was lifting on the right front corner posing a slip, trip and fall hazard.	Replace/repair the flooring to remove the tripping hazard.	Immediate
8	The Workplace (Health, Safety and Welfare) Regulations 1992, Regulation 12	The threshold of the walk in freezer was damaged and holed posing a slip, trip and fall hazard.	The threshold needs to be repaired/replaced.	Immediate
Food Standards				
Advice		Some of the ingredients you use may be or may contain known allergens. Where products are produced and sold directly to consumers allergy labelling is not currently required. Staff, however, need to be aware of the contents of all food so they can correctly advise customers on which allergens are included in which foods.		